



LG Chem, Ltd.

128, Yeoui-daero, Yeongdeungpo-gu,
Seoul, Korea.

Global Standard Certification Part

Tel: 82-42-870-6195, Fax: 82-42-863-0182

If any of pages is not legible or has not been received,
please notify our office for re-transmission

November 30 , 2015

CERTIFICATE OF COMPLIANCE

The following product has been evaluated according to the 5th revised edition
Amendment 2 of the UN Manual of Tests and Criteria.

We, LG Chem, Ltd. hereby certify that this cell meets the requirements of the
regulation for transportation of lithium-ion cells and batteries.

Model Name	:	M48126P3B CMA
Cell Model name	:	JH3
Electric power Capacity	:	3.26 kWh
Type of Cell	:	Pouch
Document No.	:	QAE-EF02-151130-B-M48126P3B CMA

Conducted By: Jae Seung Lee

Manager
Global Standard Certification Part
LG Chem, Ltd.
E-mail: Paradiso@lgchem.com

Reviewed By: Dae Ho Nam

Senior Manager
Global Standard Certification Part
LG Chem, Ltd.
E-mail: kkammy@lgchem.com

Test Result

For more information, please refer to Document QAE-EF02-151130-B-M48126P3B CMA

<input type="checkbox"/> Lithium-ion cell	<input checked="" type="checkbox"/> Lithium-ion battery
Model name	M48126P3B CMA
Cell Model name	JH3
Nominal voltage	25.9 V
Electric power capacity	3.26 kWh

No.	Test Item	Criteria	Result	Remark
Test 1	Altitude simulation	- No leakage (If $M < 1g$, less than 0.5%, If $1g \leq M \leq 75g$, less than 0.2%, If $M > 75g$, less than 0.1%), venting, disassembly, rupture and no fire. -Measuring mass before/after each test. -Measuring voltage before/after each test. (more than 90%)	Pass	
Test 2	Thermal test		Pass	
Test 3	Vibration		Pass	
Test 4	Shock		Pass	
Test 5	External Short Circuit	-No disassembly, rupture and fire within six hours of this test. -Max. temperature should not exceed 170°C.	Pass	
Test 6	Crush	-No disassembly and fire within six hours of this test. -Max. temperature should not exceed 170°C.	Pass	
Test 7	Overcharge	-No disassembly and fire within seven days of the test.	Pass	Battery only
Test 8	Forced discharge	-No disassembly and fire within seven days of the test.	Pass	

Tests through T1-T5 shall be conducted in sequence with the same battery.

We declare that the above-mentioned test is the result of being checked according to UN Test (Manual of Test and Criteria ST/SG/AC.10/11/Rev.5/Amendment2)

We certify that this cell is proved to meet the requirements of each applicable test in the UN Manual of Test and Criteria, Part III, sub-section 38.3

Conducted By: Jae Seung Lee



Manager
Global Standard Certification Part
LG Chem, Ltd.
E-mail: Paradiso@lgchem.com

Reviewed By: Dae Ho Nam



Senior Manager
Global Standard Certification Part
LG Chem, Ltd.
E-mail: kkammy@lgchem.com