



## **Attestation of Conformity**

No. N8AUK 086470 0101 Rev. 00

Holder of Certificate:

#### Ginlong Technologies Co., Ltd.

No.57 Jintong Road Binhai Industrial Park, Xiangshan 315712 Ningbo, Zhejiang PEOPLE'S REPUBLIC OF CHINA

**Product:** 

### Converter Hybrid Inverter

This Attestation of Conformity is issued on a voluntary basis according to the Electrical Equipment (Safety) Regulations 2016 relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the regulations and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.:

704092103639-00

Date,

2022-04-11

XX WO

(Zhengdong Ma)

Page 1 of 3 After prepar

After preparation of the necessary UK regulation technical documentation as well as the UK declaration of conformity the required UKCA marking can be affixed on the product. Other applicable UK regulations have to be observed.





# **Attestation of Conformity**

No. N8AUK 086470 0101 Rev. 00

Model(s):

S5-EH1P3K-L-UN, S5-EH1P3K-L-UN-EX, S5-EH1P3.6K-L-UN, S5-EH1P3.6K-L-UN-EX, S5-EH1P4.6K-L-UN, S5-EH1P4.6K-L-UN-EX, S5-EH1P5K-L-UN, S5-EH1P5K-L-UN-EX, S5-EH1P6K-L-UN, S5-EH1P6K-L-UN-EX

#### **Parameters:**

PV inputs:	
Max. input voltage	d.c. 600V
MPP voltage range	d.c. 90-520V
Max. input current	d.c. 2x15A
Isc PV (absolute maximum)	d.c. 2x22.5A
Battery	
Battery type	Li-ion
Battery voltage range	d.c. 42-58V
Max. charge/discharge current	d.c. 62.5A/62.5A(S5-EH1P3K-L-UN, S5-EH1P3K-L-UN-EX, S5-EH1P3.6K-L-UN, S5-EH1P3.6K-L-UN-EX), d.c.100A/100A(S5-EH1P4.6K-L-UN, S5-EH1P4.6K-L-UN- EX,S5-EH1P5K-L-UN, S5-EH1P5K-L-UN-EX,S5-EH1P6K-L-UN, S5-EH1P6K-L-UN-EX)
AC-output (grid side)	
Rated output voltage	a.c. 230V
Rated output frequency	50/60 Hz
Rated output power	3000W (S5-EH1P3K-L-UN, S5-EH1P3K-L-UN-EX), 3600W (S5-EH1P3.6K-L-UN, S5-EH1P3.6K-L-UN-EX), 4600W (S5-EH1P4.6K-L-UN, S5-EH1P4.6K-L-UN-EX), 5000W (S5-EH1P5K-L-UN, S5-EH1P5K-L-UN-EX), 6000W (S5-EH1P6K-L-UN, S5-EH1P6K-L-UN-EX)
Max. apparent output power	3300VA (S5-EH1P3K-L-UN, S5-EH1P3K-L-UN-EX), 4000VA (S5-EH1P3.6K-L-UN, S5-EH1P3.6K-L-UN-EX), 4600VA (S5-EH1P4.6K-L-UN, S5-EH1P4.6K-L-UN-EX), 5500VA (S5-EH1P5K-L-UN, S5-EH1P5K-L-UN-EX), 6000VA (S5-EH1P6K-L-UN, S5-EH1P6K-L-UN-EX)
Max. output current:	a.c. 15.0A (S5-EH1P3K-L-UN, S5-EH1P3K-L-UN-EX), a.c. 18.2A (S5-EH1P3.6K-L-UN, S5-EH1P3.6K-L-UN-EX), a.c. 21A (S5-EH1P4.6K-L-UN, S5-EH1P4.6K-L-UN-EX), a.c. 25A (S5-EH1P5K-L-UN, S5-EH1P5K-L-UN-EX), a.c. 27.3A (S5-EH1P6K-L-UN, S5-EH1P6K-L-UN-EX)
Displacement factor:	-0.81+0.8

Page 2 of 3

After preparation of the necessary UK regulation technical documentation as well as the UK declaration of conformity the required UKCA marking can be affixed on the product. Other applicable UK regulations have to be observed.





# Attestation of Conformity

No. N8AUK 086470 0101 Rev. 00

AC-output (back-up)	
Rated output voltage	a.c. 230V
Rated output frequency	50Hz
Rated output power	3000W (S5-EH1P3K-L-UN, S5-EH1P3K-L-UN-EX), 3600W (S5-EH1P3.6K-L-UN, S5-EH1P3.6K-L-UN-EX), 5000W (S5-EH1P4.6K-L-UN, S5-EH1P4.6K-L-UN-EX, EH1P5K-L-UN, S5-EH1P5K-L-UN-EX, S5-EH1P6K-L-UN, S5-EH1P6K-L-UN-EX),
Rated output current	a.c. 13.1A (S5-EH1P3K-L-UN, S5-EH1P3K-L-UN-EX), a.c. 15.7A (S5-EH1P3.6K-L-UN, S5-EH1P3.6K-L-UN-EX), a.c. 21.7A (S5-EH1P4.6K-L-UN, S5-EH1P4.6K-L-UN-EX, S5-EH1P5K-L-UN, S5-EH1P5K-L-UN-EX, S5-EH1P6K-L-UN, S5-EH1P6K-L-UN-EX)
AC-input	
Rated output voltage	a.c. 230V
Rated output frequency	50Hz
Max output current	a.c. 22A (S5-EH1P3K-L-UN, S5-EH1P3K-L-UN-EX), a.c. 26A (S5-EH1P3.6K-L-UN, S5-EH1P3.6K-L-UN-EX), a.c. 34.5A (S5-EH1P4.6K-L-UN, S5-EH1P4.6K-L-UN-EX, S5-EH1P5K-L-UN, S5-EH1P5K-L-UN-EX, S5-EH1P6K-L-UN, S5-EH1P6K-L-UN-EX)
Protection class:	
Degree of protection:	 IP54
Overvoltage category:	II (PV), III (MAINS)
Ambient temperature:	-20°C+60°C(INV), System based on battery spec.

Tested according to:

BS EN 62109-1:2010 EN 62109-1:2010 BS EN 62109-2:2011 EN 62109-2:2011

Page 3 of 3

After preparation of the necessary UK regulation technical documentation as well as the UK declaration of conformity the required UKCA marking can be affixed on the product. Other applicable UK regulations have to be observed.